This is to certify that a qualified technican has inspected the heating system at the property listed

651-253-3985

COOLING TEST REPORT Name of person testing:

Property Address: 1234 LAKEVIEW DR Date:

Type of Cooling

Forced Air / Condenser:	X	Make: HEIL	
Mini Split:		Model:RE030	
Rated Input:	30,000	Serial #: H901225238	
Rated Efficiency:	10 SEER	Year: 1883	
Home Heat Gain Calculation:		28,200	

Components				With-in Spec
Thermostat Reading:	76	Actual Room Temp Reading:	76	Y / N
Capacitor Reading:	.68 / 34.28	Manufacture's Specification:	.66 / 35	Y / N
Compressor Amps Reading:	6.37	Manufacture's Specification:	16	Y / N
Fan Amps Reading:	4.1	Manufacture's Specification:	1	Y / N
Liquid Line Pressure:	100	Manufacture's Specification:		Y / N
Suction Line Pressure:	50	Manufacture's Specification:		Y / N

Contactor condition visual inspection: NO PITTING

Cooling Fins condition visual inspection: HAIL DAMAGED 10-15%

Coil at furnace visual inspection: OK - NO RUST IN DRAIN PAN